

for the proof of fire behaviour according to DIN 4102-1

Reference: FLT 3684419 (Translation of the German Prüfzeugnis - no guarantee for translation of technical terms)

Sponsor: Continental Grafix AG
Bahnhof-Park 3
CH - 6340 Baar

Order 2019-02-21 **Arrived** 2019-02-25

Description of samples: Uncoated, transparent, self-adhesive plastic film
"panoRama Cast".
(for details see page 2)

Delivered: 2019-02-25

Content of request: Proof of flammability to classify building materials to class B1 "schwerentflammbar" according to DIN 4102-1

Assessment: The tested material meets the requirements of class B1 for "schwerentflammbare" (not easily flammable) building materials according to DIN 4102-1 when glued on one side to glass surfaces
(for details see page 5)

Validity: 2024-02-29

Sampling: The samples were sent to the laboratory by the sponsor.

Remark: If the above-mentioned building material is not used as product according to MBO § 2, there is no need for a general building supervisory test certificate.
This test certificate is not valid if the examined building material is used as product in the meaning of state building regulations (MBO § 17).

This test certificate does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building regulations. This has to be verified by a:

- "allgemeine bauaufsichtliche Zulassung" (general building inspectorate approval) or
- "allgemeines bauaufsichtliches Prüfzeugnis" (general building inspectorate certificate) or
- "Zustimmung im Einzelfall" (exceptional approval).

In general building supervisory procedures this test certificate can serve as a basis for

- regulated building materials for the required attestation of conformity
- non-regulated building materials for the required verifications of applicability.

This test certificate comprises 5 pages and 2 enclosures.

Approved testing, inspection and certification body

This test certificate must not be published and copied preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents. Agreement of the test laboratory has to be given in any case if norms in which the tests are based or other technical standards have changed.



Prüfstelle für das
Brandverhalten
von Baustoffen
Dipl.-Ing. Uwe Kühnast

Steinstrasse 18
D - 14822 Borkheide
Fon: +49 33845 90901
Fax: +49 33845 90909
Mail: info@firelabs.de
PÜZ-Stelle (LBO): BRA09

CERTIFICATE
TEST

